Water Operators Report Sept. 2025

Prepared by: Dave Shepherd

			Water consump	otion					
Monthly Consumption		9,676.00 M ³		507.61 N	1 ³	Daily Average			
Previous year 2024-July		10,183 M ³	28	363.68 N	l ³	Daily Average			
Vol Well #1 since 19 Jan 2019		371.77 M ³				Last month	Last year		
Max Flow for month		1,673.90 L/Min	Min Flow for	month L/Min	1.5	3.6	30.1		
Time and Date		08:49 8th Sept		2025-09-28	11:57				
Pump hours		# 2	#3	3	#	‡ 4			
Previous month hrs		249h58	Bm	28h53m		673h53m			
			VIHA Sample	es					
Activity	Date	Location	Sample type	Result					
Monthly	08/09/2025	7941 Park	Drinking water	✓					
Sample /testing		7588 Ships Pt.	Drinking water	✓	₹				
		7576 Tozer	Drinking water	✓	Sent to VIHA				
		Well 2	Raw	✓	it to				
		Well 3	Raw	✓	Sen				
		Well 4	Raw	✓					
			Operations/Mainto	enance					
	Weekly:								
		s, CL residuals (5 locations) incl flushing station, run pump 1 collect well levels data level and add accordingly							
	•	nonth Data create report, replace CL membrane & order chlorine as needed							
Attend WTC and SPID Meetings									
02/09/2025	Call out Pumphouse Reset VFD #4 re lightening #2 automatically took over								
	CL low perform	rapid decompression a	nd prime to bring up to រុ	pressure monito	r				
03/09/2025	Unable to acces	Unable to access HMI remotely, Goto PH to discover white screen Txt Nick re okay to cycle Pwr to screen (it worked)							
	Assist JA with N	Assist JA with Notice delivery							
10/09/2025	email WP re VPN quote to proceed, program change re #4 switching at high flow to assist #3 (from 100 to 1600 LPM)								
	plus include #2	at 2000 LPN?							
15/09/2025	Sanitize and flush Tozer flushing station test CL residual, email Josh results collect 2nd IH sample and deliver to IH office								
	Program Flushir	ng station to operate ay 0	730 for 10 min on Wedne	esdays as well as	Sat.				
18/09/2025	Set up new lapt	top with: Updates, SPID	Microsoft 360, outlook	email, PIN access	s, load A	Any desk re WP access	5		

	Any desk did not work called WP tried and was unable to access will look at it when time allows			
20/09/2025	Change water conservation from stage 3 to stage 2			
24/09/2024	BC one call phoned me! Re tozer Rd home owner uncovered pipe! Determined on private property tried to determin			
	what it was (recommended call a plumber)			
28/09/2024	Call out PH reset VFD and bring CL back up to normal levels			