

Water Operators Report Jan. 2026

Prepared by: Dave Shepherd

Water consumption

Monthly Consumption	4,581 M ³		147.77 M ³	Daily Average
Previous year 2025-Jan.	4,188 M ³	28	149.59 M ³	Daily Average

Vol Well #1 since 19 Jan 2019	397 M ³			Last month	Last year
Max Flow for month	227.00 L/Min	Min Flow for month L/Min	52	41.4	0
Time and Date	24/01/2026 07:20			05/01/2026 01:04	
Pump hours	# 2 739h0m	# 3	48m	#4	3h41m
Previous month hrs	741h30m		29m		2h03m

VIHA Samples					
Activity	Date	Location	Sample type	Result	
Monthly Sample /testing	12/01/2026	7941 Park	Drinking water	✓	Sent to VIHA
		7588 Ships Pt.	Drinking water	✓	
		7576 Tozer	Drinking water	✓	
		Well 2	Raw	✓	
		Well 3	Raw	✓	
		Well 4	Raw	✓	

Operations/Maintenance

Weekly:

Meter readings, CL residuals (5 locations) incl flushing station, run pump 1 collect well levels data
 Check CL tank level and add accordingly

Monthly:

Prep chain of custody report and sample bottles Collect Island Health samples and deliver to office
 Collect end of month Data create report, replace CL membrane & order chlorine as needed
 Attend WTC and SPID Meetings

- 02/01/2026 Request Range report from IH
- 05/01/2026 Call from Baynes resident re service line specs. Call from BC Hydro re branch on PRW line in Pumphouse area
- 08/01/2026 Save July to Dec 2025 Range report from IH to Sync, Year end inventory
- 09/01/2026 Install new well logger in #1 with MM
- 11//01/2026 Call out PH Low CL
- 14/01/2025 Write up SCADA questions and more for MM to review and add
- 21/01/2026 Renew BCWAA membership 135.45
- 22/01/2026 Gen Test with JL meet BT and Ian McGill on site re New Well options
- 26/01/2026 Assist KT remove dead tree leaning over PH driveway at gate

29/01/2026 Print and save septic locations 260 Bates and 302 SPR (Re proximity to Wells) no issues